


Mr. Franseen:
 Per your request, the subject result has been provided.

Sampling Event	Date Collected	TPH Concentration (ppm)	Benzene Concentration (ppm)
1 st	7/13/2018	298.0	<0.00250
2 nd	7/16/2018	34.9	<0.00050
3 rd	7/20/2018	11.0	<0.00050
4 th	7/28/2018	20.0	<0.00050
5 th	8/3/2018	<0.0935	<0.00050



Location:

Oil Water Separator #1, Northeast Service Center – OWS-1 Capacity of Oil Water Separator: 9000 Gallons

Charlie Lee
 Project Manager, PMP
 SWMD, City of Houston

